

PSA
Water System Report
March 2022

We've received bids for painting the Two water tanks and the piping inside the pump house. It is the opinion of the Water Committee to proceed with the pump house portion of the project and wait until better weather to paint the storage tanks. The cost to do the interior piping is \$2100 from Express Painting. They are available to do the work however I have concerns giving them the go ahead until we talk about the level of preparation and protection of the groundwater from any paint or solvent spills. The work is within the well head protection zone. I want to go over a containment plan and make sure nothing is stored onsite. I prefer to wait until I return in April to go over this with them rather than over the phone.

The other issue has been the emergency generator. The transfer switch had a part fail and we have been waiting for it for some time now. Velinda has tried on numerous occasions to get information from the vendor about when we can expect the repair to be completed without success. All we can do is keep calling at this point.

For financial balances please see the Treasurers Report.

Tom Moore
Water Co-Chair