

PSA
Water System Report
May 2022

Express Painting has completed the painting of the piping inside the booster pump house. We are also planning to pressure wash and paint the water storage tanks when the weather improves.

Another issue that has been plaguing us of late is the emergency generator. The transfer switch motherboard failed and we have been waiting for it since last fall. It finally came in and has been installed and programmed. Everything is back up and running. With that done all systems at the wells and pump house are now working as they should.

In the coming days as time permits I expect to solicit bids for the clean up of our well sites. We do that twice a year in June and late September.

For financial balances please see the Treasurers Report.

Tom Moore
Water Co-Chair